



**BLOCK WATER TESTING LABORATORY, BATALA**  
Judicial Court Complex on Police line Road, Opposite Police Station, Batala.  
bwtlbt@gmail.com

TEST REPORT						
Name & Address of Customer : <b>Divine Public School, Malewal Malewal</b>			Customer Reference No.		No : DPS/25/3520 Dated : 12/03/2025	
			Sample Submitted by		Kanwarsher Singh	
			Date of Sample Receipt		12/03/2025	
			Analysis Starting Date		19/03/2025	
			Analysis completion Date		19/03/2025	
Discipline : <b>Chemical Testing</b>			Group: <b>Water</b>			
ULR No.:	NABLDWT0026025034F		Sample Type :		Water	
Test Report No.:	BWTBTL/2425/00160		Date of Issue :		19/03/2025	
Registration no.:	BWTBTL/REG2425/00415		Condition of Sample :		Sealed	
Collection Point:	Private Submersible		Quantity/Type of Bottle:		1000 ml / Plastic Bottles	
Scheme/Source:	Not Mentioned(Not Mentioned)		Location/Depth :		NA / 350 ft	
Village :	Malewal		Habitation :		Malewal	
Block:	Fategarh Churrian		District :		Gurdaspur	
Latitude :	Not Mentioned		Longitude:		Not Mentioned	
Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.25	6.5-8.5	No Relaxation	—	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	—	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	—	IS 3025 (Part 8 – 2023)
5	TDS	320	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.5	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO <sub>3</sub> )	280	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO <sub>3</sub> )	216	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	57.70	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	17.49	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	69.96	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method


This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

  
**PRINCIPAL**  
**DIVINE PUBLIC SCHOOL**  
**MALEWAL (GSP.)**  
**CBSE : 1630686**

  
**Manager**  
**Divine Public School,**  
**Malewal (Gsp.)**

Reviewed and Approved By

  
**Mr. Pankaj Kumar**  
**Quality Manager**  
**Authorized Signatory**  
**For,Block Water Testing Laboratory**  
**Batala**

End of the Test Report